

STATE OF COLORADO

DEPARTMENT OF TRANSPORTATION
Materials and Geotechnical Branch
Staff Materials Lab
4670 North Holly Street
Denver, CO 80216-6408
303-398-6566 Fax 303-398-6504



July 22, 2009

Mr. Caleb Wright
Kodi Klip Corporation
314 South Cumberland St.
Lebanon, TN 37087

Dear Sir,

Rebar fastening devices made of plastic are acceptable on CDOT projects without having to be on our Approved Products List. The Kodi Klip complies with Subsection 602.02 of CDOT's Standard Specifications for Road and Bridge Construction. This specification states "All accessories, including reinforcing steel supports, ties, and splicers used in conjunction with epoxy coated reinforcing steel, shall be plastic or epoxy coated."

The use of this product on CDOT projects is acceptable as long as the product is equivalent or stronger to the samples provided for evaluation with the submittal application.

Thank you,

A handwritten signature in black ink, which appears to read 'David Kotzer', is positioned above the typed name and title.

David Kotzer
Materials Documentation & Publication Mgr
Product Evaluation Coordinator
Colorado DOT
4670 North Holly Street
Denver, CO 80216-6408