



**Washington State  
Department of Transportation**

**Douglas B. MacDonald**  
Secretary of Transportation

Environmental & Engineering  
Materials Laboratory  
PO Box 47355  
Olympia, WA 98504-7365

360-709-5400  
360-709-5588  
TTY: 1-800-833-6388  
[www.wsdot.wa.gov](http://www.wsdot.wa.gov)

June 1, 2005

Kodi Klip  
314 South Cumberland Street  
Lebanon, TN 37087

RE: Product Evaluation Program

Dear Ladies and Gentlemen:

Thank you for your interest in the Washington State Department of Transportation (WSDOT) New Product Evaluation Program. The committee has completed the review of the application and associated literature for Kodi Klip. The committee's recommendation is as follows:

This product has been "Approved with Limitations". This product can only be used in bridge roadway slabs and is subject to the spacing and tie location requirements specified in WSDOT Standard Specifications Section 6-02.3(24)C for tie wire. We have attached a copy of the New Product Bulletin for your review.

If you have any questions regarding your product, please feel free to contact John Livingston at (360) 709-5472. All future inquiries should reference Number 2005-21.

Sincerely,

*by: [Handwritten Signature]*

Thomas E. Baker, P.E.  
State Materials Engineer

TEB:jl

JRL

cc: M. Bauer, 47340  
G. Smith, 47415